



South Asia

Choose certainty.
Add value.

Test Report No. BLR/F(M)/18/023242

Dated 2018-09-27

Issued To : DINDIGUL FARM PRODUCT PRIVATE LIMITED
S F No: 767-769,
Karuthanaicken Patty Road,
Sendurai Village, Natham Taluk,
Dindigul District,
Dindigul, Tamil Nadu,
India - 624403.

Attention : K. Muthu,

Customer Ref. No. : Test Request Form, Dated 2018-09-20

Sample Particulars

Sample Name : Air Monitoring Plate - Powder Packing Room AHU duct outlet

Batch No. / Lot No. / Mfg. Date / Best Before Date : Not Available

Sample Package / Quantity : Petri Plate, Two Number

Sampled by : Representative of TÜV SÜD South Asia Pvt Ltd (Mr. Vimalraj. J)

Sampling Location : Powder Packing Room AHU duct outlet @ M/s. Dindigul Farm Product Private Limited - Sendurai, 624403, Sampling Date & Time: 20.09.2018 & 01:45 pm to 03:02 pm

Sampling Protocol : Not Applicable

Sample Condition : Good

Date of Sample Receipt : Received on 2018-09-21

Date of Analysis : 2018-09-22

Date of Completion : 2018-09-27

Authorised By

Ajith S
Authorized Signatory

By accepting this document the customer hereby agrees and accepts the 'Terms & Conditions' and the relevant 'Testing & Certification Regulations' of TÜV SÜD South Asia Pvt. Ltd. which are available at Company's website at the link- <http://www.tuv-sud.in/in-en/resource-centre/terms-and-conditions>.

Note: The test report is electronically generated. Hence original signature is not required. For any technical query, please contact Satya Srinivas at Satya.Srinivas@tuv-sud.in and for any complaint please contact Nagaraj R at R.Nagaraj@tuv-sud.in.

Note : (1) The results relate only to the items tested, (2) the test report shall not be reproduced except in full without the written approval of the laboratory, (3) For details of the accredited scope, please contact laboratory or accreditation body website

Laboratory:
TÜV SÜD South Asia Pvt. Ltd.
No. A 151, 2nd C Main,
2nd Stage,
Peenya Industrial Estate
Bangalore,

Phone :+91 80 67458096
Fax :+91 80 67458058
E-Mail :satya.srinivas@tuv-sud.in
Url : www.tuv-sud.in
ControlNo:15360250.210918.238

Regd. Office:
TUV SUD South Asia Pvt. Ltd.
Off Saki Vihar Road, Saki
naka, Andheri (East),
Mumbai-400072. India

TUV®



South Asia

Test Report No. BLR/F(M)/18/023242

Dated 2018-09-27

S. NO.	PARAMETERS	TEST RESULT	TEST METHOD
	Microbiology :		
1	Total Plate Count,cfu/15 minutes of Exposure	26	Chapter 8, APHA 5th Edition, 2015
2	Yeast & Mould Count,cfu/15 minutes of Exposure	25	Chapter 21, APHA 5th Edition, 2015

Authorised By

Ganga Bhaskar
(Authorized Signatory -
Microbiology)

- END OF TEST REPORT -